



SETSCO SERVICES PTE LTD

18 Teban Gardens Crescent
Singapore 608925
Tel : (65) 6566 7777
Fax: (65) 6566 7718
Website: www.setsco.com
Business Reg. No. 196900269D

Our Ref : CH-51857/YSP/1

Date : 11/07/2016

TEST REPORT

(This Report is issued subject to the terms & conditions set out below)

Page 1 of 2

- Subject** : Analysis according to SGBC requirement - Adhesives & Sealants (Clause 4.4.1b and Clause 4.4.2) on sample submitted by Airflex Pte Ltd on 15/06/2016 and test commenced on 16/06/2016.
- Tested For** : **Airflex Pte Ltd**
Blk 1046 Eunos Ave 5
#01-137
Singapore 409746
Attn : Ms Vivian Kew
- Sample Description** : 1st Acrylic Sealant
A-700 Green
- Result** : Refer to the following page.

Terms & conditions:

- (1) The Report is prepared for the sole use of the Client and is prepared based upon the Item submitted, the services required by the Client and the conditions under which the Services are performed by SETSCO. The Report is not intended to be representative of similar or equivalent Services on similar or equivalent items. The Report does not constitute an endorsement by SETSCO of the item.
- (2) SETSCO agrees to use reasonable diligence in the performance of the Services but no warranties are given and done may be implied directly or indirectly relating to the Services, the Report or the facilities of SETSCO.
- (3) The Report may not be used in any publicity material without the written consent of SETSCO.
- (4) The Report may not be reproduced in part or in full unless approval in writing has been given by SETSCO.
- (5) SETSCO shall under no circumstances be liable to the Client or its agents, servants or representatives, in contract, tort (including negligence or breach of statutory duty) or otherwise for any direct or indirect loss or damage suffered by the Client, its agents, servants or representative howsoever arising or whether connected with the Services provided by SETSCO herein.

Results :

Clause	Parameter	Unit	Result	Reporting Limit	Specification	Justification
4.4.1b	Phthalates	%wt	Not Detected	0.03	Not Detected	Pass
	Alkylphenolethoxylates*	%wt	Not Detected	0.1	Not Detected	Pass
	Halogenated Solvents	%wt	Not Detected	0.1	Not Detected	Pass
4.4.2	VOCs	g/L	<1	1	Refer to Table 1	

Table 1

Gloss Unit	VOC Limit (g/L)
Matt (Interior / Exterior)	25 / 50
Low Sheen (Interior / Exterior)	30 / 50
Semi -Gloss (Interior / Exterior)	75 / 75

Note : *Tests were performed in conjunction with Marchwood Laboratory Services Pte Ltd



YU SIOW PEI
ASSISTANT MANAGER
BIOLOGICAL & CHEMICAL TECHNOLOGY DIVISION